



**MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER**

See last page for instructions.

**I. General Information for the Month/Year of: Aug-16**


<b>A. Public Water System (PWS) Information</b>			
PWS Name:	<b>University Oaks</b>	PWS Identification Number	<b>2381208</b>
PWS Type:	<input checked="" type="checkbox"/> Community <input type="checkbox"/> Non-Transient <input type="checkbox"/> Transient Non-Community <input type="checkbox"/> Consecutive		
Number of Service Connections at End of Month:	<b>123</b>	Total Population Served at End of Month:	<b>369</b>
PWS Owner:	Levy County Board of County Commissioners		
Contact Person:	Jimmy Jones	Contact Person's Title:	Housing Specialist
Contact Person's Mailing Address:	P.O. Drawer 160	City:	Bronson State: Florida Zip Code: 32621
Contact Person's Telephone Number:	352-486-5100	Contact Person's Fax Number:	None
Contact Person's E-Mail Address:	None		

**B. Water Treatment Plant Information**

Plant Name:	<b>University Oaks</b>		Plant Telephone	352-486-5376
Plant Address:	1011 NE 109th Street	City:	Archer	State: Florida Zip Code: 32618
Type of Water Treated by Plant:	<input checked="" type="checkbox"/> Raw Ground Water <input type="checkbox"/> Purchased Finished Water			
Permitted Maximum Day Operating Capacity of	<b>228,171</b>			
Plant Category (per subsection 62-699.310(4),	<b>V</b>	Plant Class (per subsection 62-699.310(4), F.A.C.):	<b>D</b>	
Licensed Operators	Name	License Number	License Class	Day(s)/Shift(s) Worked
Lead/Chief Operator:	Richard M. Tisdale, Sr.	C	2226	Monday-Friday
Other Operators:	Richard M. Tisdale, Jr	C	6937	Monday-Friday
	Wayne R. Davids	C	12391	Monday-Friday
	Anthony T. Hubbard	C	12902	Monday-Friday
	Thaddeus W. Tisdale	C	14738	Monday-Friday
	Ross A Bogert	C	18962	Monday-Friday
	Danny M. Woodworth	C	21287	Monday-Friday
	Brenton W. Moring	C	22834	Monday-Friday

**II. Certification by Lead/Chief Operator**

I, the undersigned water treatment plant operator licensed in Florida, am the lead/chief operator of the water treatment plant identified in Part I of this report. I certify that the information provided in this report is true and accurate to the best of my knowledge and belief. I certify that all drinking water treatment chemicals used at this plant conform to NSF International Standard 60 or other applicable standards referenced in subsection 62-555.320(3), F.A.C. I also certify that the following additional operations records for this plant were prepared each day that a licensed operator staffed or visited this plant during the month indicated above: (1) records of amounts of chemicals used and chemical feed rates; and (2) if applicable, appropriate treatment process performance records. Furthermore, I agree to provide these additional operations records to the PWS owner so the PWS owner can retain them, together with copies of this report, at a convenient location for at least ten years.

 Signature and Date	9/7/2016	Ross A. Bogert Printed or Typed Name	C 18962 License Number
-----------------------------------------------------------------------------------------------------------	----------	-----------------------------------------	---------------------------

**MONTHLY OPERATION REPORT FOR PWSs TREATING RAW GROUND WATER OR PURCHASED FINISHED WATER**

PWS Identification Number: **2381208** Plant Name: **University Oaks**

III. Daily Data for the Month/Year of: **August 2016**

Means of Achieving Four-Log Virus  Free Chlorine  Chlorine Dioxide  Ozone  Combined Chlorine (Chloramines)  Ultraviolet Radiation  Other:

Type of Disinfectant Residual Maintained in  Free Chlorine  Combined Chlorine (Chloramines)  Chlorine Dioxide

Day of the Month	Days Plant Staffed or Visited by Operator (Place "X")	Hours Plant in Operation	Net Quantity of Finished Water Produced, gal	CPC Calculations (or UV Dose to Demonstrate Four-Log Virus Inactivation) (or Not Applicable)										Lowest Residual Disinfectant Concentration at Remote Point in Distribution System, mg/L	Emergency or Abnormal Operating Conditions; Repair or Maintenance Work that Involves Taking Water System Components Out of Operation	
				Disinfectant Concentration (C) Before or Just After Custom Flow, mg/L	Disinfectant Contact Time (T) in Minutes	Temperature of Water, °C	pH of Water	UV Dose (mJ/cm²)	Minimum UV Dose Required (mJ/cm²)	UV Dose Received (mJ/cm²)	UV Dose Margin					
1	X	24	36,333												0.60	
2		24	39,500													
3	X	24	39,500												0.60	
4		24	39,500													
5	X	24	39,500												0.70	
6		24	36,333													
7		24	36,333													
8	X	24	36,333												0.70	
9		24	37,000													
10	X	24	37,000												0.70	
11		24	39,500													
12	X	24	39,500												0.70	
13		24	42,000													
14		24	42,000													
15	X	24	42,000												0.70	
16		24	38,000													
17	X	24	38,000												0.80	
18		24	48,000													
19	X	24	48,000												0.80	
20		24	46,333													
21		24	46,333													
22	X	24	46,333												0.80	
23		24	50,000													
24	X	24	50,000												0.80	
25		24	45,500													
26	X	24	45,500												0.80	
27		24	46,000													
28		24	46,000													
29	X	24	46,000												0.60	
30		24	39,000													
31	X	24	39,000												0.60	
<b>Total</b>			1,300,331													
<b>Average</b>			41,946													
<b>Maximum</b>			50,000													

LOWEST RESIDUAL 0.6 days checked by operator 14  
 DAYS IN MONTH 31